Alarm Code 5d	Compressor Protection

★ This alarm code appears when one of the following alarms occurs three times within 6 hours, which may result in serious compressor damages, if the outdoor unit is continuously operated without removing the cause.

Alarm Code	Content of Abnormality
14	Activation of Protection Device (High Pressure Switch) in Outdoor Unit
5C	Decrease in Discharge Gas Superheat
47	Excessively High Discharge Gas Temperature at Top of Compressor
7C	Activation of Pressure Ratio Decrease Protection
7B	Activation of Low Pressure Increase Protection
7A	Activation of High Pressure Increase Protection Device
6E	Activation of Low Pressure Decrease Protection

These alarms are able to be checked by the CHECK Mode. Follow the action indicated in each alarm chart.
These alarms are cleared only by turning OFF the main power supply to the system. Do not restart the operation without taking any necessary action, since there is a possibility of causing serious damages to the compressors.