Alarm code	70	Water pressure alarm

- Alarm code is displayed on the master controller/ the 7-segment of O.U. display PCB / the 7-segment of I.U. PCB1.
- This alarm is displayed when there is a low water pressure(Pw<0.3bar) or high water pressure(Pw≥4bar) abnormality in the hydraulic system for 3 min and the same condition occurs three times or more within 60 minutes.
  Note:The detection is invalid when DSW3-3 ON.
- Reset the unit to release the alarm.

