Alarm code	74	Mixing overheating limit protection for mixed circuit (Only if cycle 2 is enabled)

- Alarm code is displayed on the master controller/ the 7-segment of O.U. display PCB / the 7-segment of I.U. PCB1.
- This alarm code is displayed when outlet water temperature of water cycle 2 (Tow2) is too high as following and the same condition occurs one time or more within 60 minutes.
  (1) None of [OFF] is set by [Overheat protection offset].
  (2) Detecting Tow2 is higher than [Max. Water Supply Temp of water cycle 2 + Overheat protection offset] for 10 minutes. referring to 10.2.2.2 Second water temperature control.
- Reset the unit to release the alarm.

