Alarm Code	Compressor Protection

★ This alarm code appears when one of the following alarms occurs three times within 6 hours, which may result in serious compressor damages, if the outdoor unit is continuously operated without removing the cause.

Alarm Code	Content of Abnormality
02	Activation of Protection Device (High Pressure Switch) in Outdoor Unit
07	Decrease in Discharge Gas Superheat
08	Excessively High Discharge Gas Temperature at Top of Compressor
43	Activation of Pressure Ratio Decrease Protection
44	Activation of Low Pressure Increase Protection
45	Activation of High Pressure Increase Protection Device
47	Activation of Low Pressure Decrease Protection

These alarms are able to be checked by the CHECK Mode. Follow the action indicated in each alarm chart.
These alarms are cleared only by turning OFF the main power supply to the system. Do not restart the operation without taking any necessary action, since there is a possibility of causing serious damages to the compressors.